

Kitemark™ Certificate

This is to certify that:

Dongguan Kenic Electric Mfg. Co., Ltd.
72 Huan Cun Xi Road
JinXia Changan
Dongguan
Guangdong
523843
China

Holds Certificate Number:

KM 54019

In respect of:

BS 1363 Parts 1-5
Plugs, Socket-outlets, Adaptors and Fused Connection units.

This issues the right and licence to use the Kitemark in accordance with the Kitemark Terms and Conditions governing the use of the Kitemark, as may be updated from time to time by BSI Assurance UK Ltd (the "Conditions"). All defined terms in this Certificate shall have the same meaning as in the Conditions.

The use of the Kitemark is authorized in respect of the Product(s) detailed on this Certificate provided at or from the above address.



For and on behalf of BSI:

Shahm Barhom, Group Product Certification Director

First Issued: 2000-03-09

Latest Issue: 2023-02-02

Effective Date: 2023-02-02

Expiry Date: 2025-12-10

Page: 1 of 12




Kitemark™ Certificate

No. KM 54019

The affixing of the Kitemark and the words 'Approved by BSI Lic No KM 54019' signify that the 13 A plugs detailed on this Kitemark Certificate are approved by BSI within the meaning of the Statutory Instrument No. 1768 1994 being 'The Plug and Socket etc (Safety) Regulations 1994'.

Approval remains in force concurrent with the expiration date of this Kitemark licence.

It is a condition of approval that the Licensee maintains strict compliance with the requirements of both the Plug and Socket etc (Safety) Regulations 1994 and the Kitemark Conditions of Contract



Group 1: Non-rewireable plugs to BS 1363-1:2016 + A1:2018

Type	Rating	Colour	Reference Report
KE-88 - GEM* Insert KE-88 – Kenic MA-088** Insert	250 V (Rough use)	Any colour including black	241/005456, 241/4241338, 241/4322211, 241/4463261, 241/4645476, 241/4657739, 241/4919107, 241/7150356*, 241/7378680, 241/7483462, 241/7612503, 8216833, 8216898** & 8420353 (GJW2015-4985BSI).

Cable fitted: The following cables are satisfactory for incorporation with the variants of Group 1 and are subject to the continuing validity of their approval.

Standard	Size mm²	Code	Manufacturer	Approval	Rating (A)
EN 50525-2-21	2 x 0.75	H05RN-F	Ta Tun	VDE 40017124	6
EN 50525-2-21	2 x 1	H05RN-F	Ta Tun	VDE 40017124	10
EN 50525-2-21	3 x 0.75	H05RN-F	Ta Tun	VDE 40017124	6
EN 50525-2-21	3 x 1	H05RN-F	Ta Tun	VDE 40017124	10
EN 50525-2-21	3 x 0.75	H05RR-F	Ta Tun	VDE 40017124	6
EN 50525-2-21	3 x 1	H05RR-F	Ta Tun	VDE 40017124	10
EN 50525-2-22	3 x 0.75	H03RT-H	Ta Tun	VDE 40006216	6
EN 50525-2-22	3 x 1	H03RT-H	Ta Tun	VDE 40006216	10
EN 50525-2-11	2 x 0.75	H03VVH2-F	Kenic	VDE 103853	6
EN 50525-2-11	2 x 0.75	H03VV-F	Kenic	VDE 103853	6
EN 50525-2-11	3 x 0.75	H03VV-F	Kenic	VDE 103853	6
EN 50525-2-11	2 x 0.75	H05VVH2-F	Kenic	VDE 103853	6
EN 50525-2-11	2 x 0.75	H05VV-F	Kenic	VDE 103853	6

First Issued: 2000-03-09


Latest Issue: 2023-02-02

Effective Date: 2023-02-02

Expiry Date: 2025-12-10

Kitemark™ Certificate

No. KM 54019



Cable fitted (continued): The following cables are satisfactory for incorporation with the variants of Group 1 and are subject to the continuing validity of their approval

Standard	Size mm ²	Code	Manufacturer	Approval	Rating (A)
EN 50525-2-11	3 x 0.75	H05VV-F	Kenic	VDE 103853	6
EN 50525-2-11	2 x 1	H05VV-F	Kenic	VDE 103853	10
EN 50525-2-11	3 x 1	H05VV-F	Kenic	VDE 103853	10
EN 50525-2-21	2 x 0.75	H05RR-F	Ta Tun	VDE 40017124	6
EN 50525-2-21	2 x 1	H05RR-F	Ta Tun	VDE 40017124	10
EN 50525-2-21	3 x 1	H07RN-F	Lucky United	VDE 40016757	10
EN 50525-2-21	3 x 0.75	H05RR-F	Lucky United	VDE 40016757	6
EN 50525-2-21	3 x 1	H05RR-F	Lucky United	VDE 40016757	10
EN 50525-2-21	3 x 0.75	H05RN-F	Lucky United	VDE 40016757	6
EN 50525-2-21	3 x 1	H05RN-F	Lucky United	VDE 40016757	10
EN 50525-2-22	3 x 0.75	H03RT-H	Lucky United	VDE 40018618	6
EN 50525-2-22	3 x 1	H03RT-H	Lucky United	VDE 40018618	10
EN 50525-2-11	3 x 1.5	H05VV-F	Kenic	VDE 103853	13
EN 50525-2-21	2 x 1.5	H07RN-F	Lucky United	VDE 40016757	13
EN 50525-2-22	3 x 1.5	H03RT-H	Lucky United	VDE 40018618	13
EN 50525-2-21	3 x 1.5	H05RR-F	Lucky United	VDE 40016757	13
EN 50525-2-21	3 x 1.5	H07RN-F	Lucky United	VDE 40016757	13
EN 50525-2-21	2 x 1	H07RN-F	Lucky United	VDE 40016757	10
EN 50525-2-21	2 x 0.75	H05RR-F	Lucky United	VDE 40016757	10
EN 50525-2-21	2 x 1	H05RR-F	Lucky United	VDE 40016757	10
EN 50525-2-21	2 x 0.75	H05RN-F	Lucky United	VDE 40016757	10
EN 50525-2-21	2 x 1	H05RN-F	Lucky United	VDE 40016757	10

First Issued: 2000-03-09

Latest Issue: 2023-02-02

Effective Date: 2023-02-02

Expiry Date: 2025-12-10

Kitemark™ Certificate

No. KM 54019

Group 2 - Rewireable 13 A Plugs to BS 1363-1:2016 + A1:2018

Type	Rating	Material	Colour	BSI Reference Report
KE-108	250 V Rough Use	Polycarbonate, Cat No. 241R, Sabic Innovative Plastics BV.	Any colour including black	241/4270740, 241/4315926 & 8216833.
KE-108	250 V Rough Use	Polycarbonate, Cat No. 2865, Bayer Thai Co. Ltd.	Black	241/4715951 & 8216833.
KE-108	250 V Rough Use	Nylon, Cat No. 101F, E I Du Pont de Nemours & Co Inc.	Black & White	241/4353125, 241/4408839 & 8216833.

工程文件

* COPY *

东莞健力电业制品有限公司

KENIC ELECTRIC MFG. CO., LTD.

Group 3: Non-rewireable plugs with ISOD, Class II, to BS 1363-1:2016 + A1:2018

Type	Rating	Colour	Reference Report
KE-208	250 V (Rough use)	All colours	241/7272447, 241/7479813, 241/7571420, 241/7634555 & 8216833.

Cable fitted: The following cables are satisfactory for incorporation with the variants of Group 3 and are subject to the continuing validity of their approval

Standard	Size mm ²	Code	Manufacturer	Approval	Rating (A)
EN 50525-2-11	2 x 0,5	H03VVH2-F	Kenic	VDE 103853	03
EN 50525-2-11	2 x 0,75	H03VVH2-F	Kenic	VDE 103853	6
EN 50525-2-11	2 x 0,75	H05VVH2-F	Kenic	VDE 103853	6
EN 50525-2-11	2 x 1	H05VVH2-F	Kenic	VDE 103853	10
EN 50525-2-11	2 x 0,5	H03VV-F	Kenic	VDE 103853	03
EN 50525-2-11	2 x 0,75	H03VV-F	Kenic	VDE 103853	6
EN 50525-2-11	2 x 0,75	H05VV-F	Kenic	VDE 103853	6
EN 50525-2-11	2 x 1	H05VV-F	Kenic	VDE 103853	10

First Issued: 2000-03-09

Latest Issue: 2023-02-02

Effective Date: 2023-02-02

Expiry Date: 2025-12-10

Page: 4 of 12

This certificate has been issued by and remains the property of BSI Assurance UK Ltd, Kitemark Court, Davy Avenue, Knowlhill, Milton Keynes MK5 8PP, United Kingdom and should be returned immediately upon request.
To check its validity telephone +44 (0) 345 080 9000. An electronic certificate can be authenticated [online](#).

BSI Assurance UK Limited, registered in England under number 7805321 at 389 Chiswick High Road, London W4 4AL, UK.
A member of BSI Group of Companies.

Kitemark™ Certificate

No. KM 54019



Group 4a: Non-rewireable plugs to BS 1363-1:2016 + A1:2018

Type	Rating	Colour	Reference Report
KE-128	250 V (Rough use)	All colours	241/7625512, 241/7729771, CAP dated 17 October 2011, 7829261 & 8216833.

Cable fitted: The following cables are satisfactory for incorporation with the variants of Group 4a and are subject to the continuing validity of their approval

Standard	Size mm ²	Code	Manufacturer	Approval	Rating (A)
EN 50525-2-11	2 x 0.75	H03VV-F	Kenic	VDE 103853	6 / 10 NOTE
EN 50525-2-11	3 x 0.75	H03VV-F	Kenic	VDE 103853	6 / 10 NOTE
EN 50525-2-11	2 x 0.75	H03VVH2-F	Kenic	VDE 103853	6 / 10 NOTE
EN 50525-2-11	2 x 0.75	H05VV-F	Kenic	VDE 103853	6 / 10 NOTE
EN 50525-2-11	2 x 1	H05VV-F	Kenic	VDE 103853	10
EN 50525-2-11	3 x 0.75	H05VV-F	Kenic	VDE 103853	6 / 10 NOTE
EN 50525-2-11	3 x 1	H05VV-F	Kenic	VDE 103853	10
EN 50525-2-11	2 x 0.75	H05VVH2-F	Kenic	VDE 103853	6 / 10 NOTE
EN 50525-2-22	3 x 0.75	H03RT-H	Lucky United	VDE 40018618	6 / 10 NOTE
EN 50525-2-22	3 x 1	H03RT-H	Lucky United	VDE 40018618	10
EN 50525-2-21	2 x 0.75	H05RN-F	Lucky United	VDE 40016757	6 / 10 NOTE
EN 50525-2-21	2 x 1	H05RN-F	Lucky United	VDE 40016757	10
EN 50525-2-21	3 x 0.75	H05RN-F	Lucky United	VDE 40016757	6 / 10 NOTE
EN 50525-2-21	3 x 1	H05RN-F	Lucky United	VDE 40016757	10
EN 50525-2-21	2 x 1	H05RR-F	Lucky United	VDE 40016757	10
EN 50525-2-21	3 x 0.75	H05RR-F	Lucky United	VDE 40016757	6 / 10 NOTE
EN 50525-2-21	3 x 1	H05RR-F	Lucky United	VDE 40016757	10
EN 50525-2-22	3 x 0.75	H03RT-H	Ta Tun	VDE 40006216	6 / 10 NOTE
EN 50525-2-22	3 x 1	H03RT-H	Ta Tun	VDE 40006216	10
EN 50525-2-21	2 x 0.75	H05RN-F	Ta Tun	VDE 40017124	6 / 10 NOTE
EN 50525-2-21	3 x 0.75	H05RN-F	Ta Tun	VDE 40017124	6 / 10 NOTE

Note: Non-rewireable plugs fitted with 0.75 mm² flexible cable size may be rated 10 A when used for cable sets with a maximum flexible cable length of 2 m.

First Issued: 2000-03-09
Latest Issue: 2023-02-02

Effective Date: 2023-02-02
Expiry Date: 2025-12-10

This certificate has been issued by and remains the property of BSI Assurance UK Ltd, Kitemark Court, Davy Avenue, Knowlhill, Milton Keynes MK5 8PP, United Kingdom and should be returned immediately upon request.
To check its validity telephone +44 (0) 345 080 9000. An electronic certificate can be authenticated [online](#).

Kitemark™ Certificate

No. KM 54019



Cable fitted (continued): The following cables are satisfactory for incorporation with the variants of Group 4 and are subject to the continuing validity of their approval

Standard	Size mm²	Code	Manufacturer	Approval	Rating (A)
EN 50525-2-21	3 x 1	H05RN-F	Ta Tun	VDE 40017124	10
EN 50525-2-21	2 x 1	H05RN-F	Ta Tun	VDE 40017124	10
EN 50525-2-21	2 x 0.75	H05RR-F	Ta Tun	VDE 40017124	6 / 10 NOTE
EN 50525-2-21	2 x 1	H05RR-F	Ta Tun	VDE 40017124	10
EN 50525-2-21	3 x 0.75	H05RR-F	Ta Tun	VDE 40017124	6 / 10 NOTE
EN 50525-2-21	3 x 1	H05RR-F	Ta Tun	VDE 40017124	10
EN 50525-2-21	2 x 0.75	H05RR-F	Lucky United	VDE 40016757	10
EN 50525-2-11	3 x 0.75	H05V2V2-F	Kenic	VDE 40042134	6 / 10 NOTE
Note: Non-rewireable plugs fitted with 0.75 mm² flexible cable size may be rated 10 A when used for cable sets with a maximum flexible cable length of 2 m.					

First Issued: 2000-03-09
Latest Issue: 2023-02-02

Effective Date: 2023-02-02
Expiry Date: 2025-12-10

Kitemark™ Certificate

No. KM 54019



Group 4b: Non-rewireable plugs with ISOD, Class I, to BS 1363-1:2016 + A1:2018

Type	Rating	Colour	Reference Report
KE-128	250 V (Rough use)	All colours	241/7625512, 241/7729771, CAP dated 17 October 2011, 7829261 & 8216833.

Cable fitted: The following cables are satisfactory for incorporation with the variants of Group 4b and are subject to the continuing validity of their approval

Standard	Size mm ²	Code	Manufacturer	Approval	Rating (A)
EN 50525-2-11	2 x 0.75	H03VV-F	Kenic	VDE 103853	6 / 10 NOTE
EN 50525-2-11	2 x 0.75	H03VVH2-F	Kenic	VDE 103853	6 / 10 NOTE
EN 50525-2-11	2 x 0.75	H05VV-F	Kenic	VDE 103853	6 / 10 NOTE
EN 50525-2-11	2 x 1	H05VV-F	Kenic	VDE 103853	10
EN 50525-2-11	2 x 0.75	H05VVH2-F	Kenic	VDE 103853	6 / 10 NOTE
EN 50525-2-21	2 x 0.75	H05RN-F	Lucky United	VDE 40016757	6 / 10 NOTE
EN 50525-2-21	2 x 1	H05RN-F	Lucky United	VDE 40016757	10
EN 50525-2-21	2 x 1	H05RR-F	Lucky United	VDE 40016757	10
EN 50525-2-21	2 x 0.75	H05RN-F	Ta Tun	VDE 40017124	6 / 10 NOTE
EN 50525-2-21	2 x 1	H05RN-F	Ta Tun	VDE 40017124	10
EN 50525-2-21	2 x 0.75	H05RR-F	Ta Tun	VDE 40017124	6 / 10 NOTE
EN 50525-2-21	2 x 1	H05RR-F	Ta Tun	VDE 40017124	10
EN 50525-2-21	2 x 0.75	H05RR-F	Lucky United	VDE 40016757	10
Note: Non-rewireable plugs fitted with 0.75 mm ² flexible cable size may be rated 10 A when used for cable sets with a maximum flexible cable length of 2 m.					

First Issued: 2000-03-09
Latest Issue: 2023-02-02

Effective Date: 2023-02-02
Expiry Date: 2025-12-10

This certificate has been issued by and remains the property of BSI Assurance UK Ltd, Kitemark Court, Davy Avenue, Knowlhill, Milton Keynes MK5 8PP, United Kingdom and should be returned immediately upon request.
To check its validity telephone +44 (0) 345 080 9000. An electronic certificate can be authenticated [online](#).

Kitemark™ Certificate

No. KM 54019



Group 5a: Non-rewireable plugs to BS 1363-1:2016 + A1:2018

Type	Rating	Colour	Reference Report
KE-328 – KEC insert	250 V (Rough use)	All colours	8411711, 8536403 and 8796555.
KE-328 - GEM insert	250 V (Rough use)	All colours	As above plus 9666634.

Cable fitted: The following cables are satisfactory for incorporation with the variants of Group 5a and are subject to the continuing validity of their approval

Standard	Size mm²	Code	Manufacturer	Approval	Rating (A)
EN 50525-2-11	2 x 0.5	H03VV-F	Kenic	VDE 103853	3
EN 50525-2-11	2 x 0.75	H03VVH2-F	Kenic	VDE 103853	6 / 10 NOTE
EN 50525-2-11	3 x 0.5	H03VV-F	Kenic	VDE 103853	3
EN 50525-2-11	3 x 0.75	H03VV-F	Kenic	VDE 103853	6 / 10 NOTE
EN 50525-2-11	2 x 0.5	H03V2V2-F	Kenic	VDE 40042134	3
EN 50525-2-11	2 x 0.75	H03V2V2-F	Kenic	VDE 40042134	6 / 10 NOTE
EN 50525-2-11	3 x 0.5	H03V2V2-F	Kenic	VDE 40042134	3
EN 50525-2-11	3 x 0.75	H03V2V2-F	Kenic	VDE 40042134	6 / 10 NOTE
EN 50525-2-11	2 x 0.75	H05VV-F	Kenic	VDE 103853	6 / 10 NOTE
EN 50525-2-11	2 x 1	H05VV-F	Kenic	VDE 103853	10
EN 50525-2-11	3 x 0.75	H05VV-F	Kenic	VDE 103853	6 / 10 NOTE
EN 50525-2-11	3 x 1	H05VV-F	Kenic	VDE 103853	10
EN 50525-2-11	2 x 1	H05V2V2-F	Kenic	VDE 40042134	10
EN 50525-2-11	3 x 0.75	H05V2V2-F	Kenic	VDE 40042134	6 / 10 NOTE
EN 50525-2-11	2 x 0.75	H05V2V2-F	Kenic	VDE 40042134	6 / 10 NOTE
EN 50525-2-11	3 x 1	H05V2V2-F	Kenic	VDE 40042134	10
EN 50525-2-11	2 x 0.5	H03VVH2-F	Kenic	VDE 103853	3
EN 50525-2-11	2 x 0.75	H03VV-F	Kenic	VDE 103853	6 / 10 NOTE
EN 50525-2-11	2 x 0.5	H03V2V2H2-F	Kenic	VDE 40042134	3
EN 50525-2-11	2 x 0.75	H03V2V2H2-F	Kenic	VDE 40042134	6 / 10 NOTE
EN 50525-2-11	2 x 0.75	H05VVH2-F	Kenic	VDE 103853	6 / 10 NOTE
EN 50525-2-11	2 x 1	H05VVH2-F	Kenic	VDE 103853	10
EN 50525-2-11	2 x 0.75	H05V2V2H2-F	Kenic	VDE 40042134	6 / 10 NOTE

Note: Non-rewireable plugs fitted with 0.75 mm² flexible cable size may be rated 10 A when used for cable sets with a maximum flexible cable length of 2 m.

First Issued: 2000-03-09

Latest Issue: 2023-02-02

Effective Date: 2023-02-02

Expiry Date: 2025-12-10

Kitemark™ Certificate

No. KM 54019



Cable fitted (continued): The following cables are satisfactory for incorporation with the variants of Group 5a and are subject to the continuing validity of their approval

Standard	Size mm ²	Code	Manufacturer	Approval	Rating
EN 50525-2-11	2 x 1	H05V2V2H2-F	Kenic	VDE 40042134	10
EN 50525-2-22	2 x 0.75	H05RR-F	Ta Tun	VDE 40017124	6 / 10 NOTE
EN 50525-2-22	3 x 0.75	H05RR-F	Ta Tun	VDE 40017124	6 / 10 NOTE
EN 50525-2-22	3 x 1	H05RR-F	Ta Tun	VDE 40017124	10
EN 50525-2-22	2 x 0.75	H05RN-F	Ta Tun	VDE 40017124	6 / 10 NOTE
EN 50525-2-22	2 x 1	H05RN-F	Ta Tun	VDE 40017124	10
EN 50525-2-22	3 x 0.75	H05RN-F	Ta Tun	VDE 40017124	6 / 10 NOTE
EN 50525-2-22	3 x 1	H05RN-F	Ta Tun	VDE 40017124	10
EN 50525-2-22	3 x 0.75	H03RT-H	Ta Tun	VDE 4006216	6 / 10 NOTE
EN 50525-2-22	3 x 1	H03RT-H	Ta Tun	VDE 4006216	10
EN 50525-2-22	2 x 1	H05RR-F	Ta Tun	VDE 40017124	6 / 10 NOTE
EN 50525-2-22	3 x 0.75	H03RT-H	Lucky United	VDE 40018618	6 / 10 NOTE
EN 50525-2-22	3 x 1	H03RT-H	Lucky United	VDE 40018618	10
EN 50525-2-22	2 x 0.75	H05RR-F	Lucky United	VDE 40016757	6 / 10 NOTE
EN 50525-2-22	3 x 0.75	H05RR-F	Lucky United	VDE 40016757	6 / 10 NOTE
EN 50525-2-22	3 x 1	H05RR-F	Lucky United	VDE 40016757	10
EN 50525-2-22	2 x 0.75	H05RN-F	Lucky United	VDE 40016757	6 / 10 NOTE
EN 50525-2-22	2 x 1	H05RN-F	Lucky United	VDE 40016757	10
EN 50525-2-22	3 x 0.75	H05RN-F	Lucky United	VDE 40016757	6 / 10 NOTE
EN 50525-2-22	3 x 1	H05RN-F	Lucky United	VDE 40016757	10
EN 50525-2-22	2 x 1	H05RR-F	Lucky United	VDE 40016757	10
EN 50525-2-21	3 x 0.75	H05BB-F	Lucky United	VDE 40016237	6 / 10 NOTE
EN 50525-2-21	3 x 1	H05BB-F	Lucky United	VDE 40016237	10
EN 50525-2-21	2 x 0.75	H05BB-F	Lucky United	VDE 40016237	6 / 10 NOTE
EN 50525-2-21	2 x 1	H05BB-F	Lucky United	VDE 40016237	10

Note: Non-rewireable plugs fitted with 0.75 mm² flexible cable size may be rated 10 A when used for cable sets with a maximum flexible cable length of 2 m.

First Issued: 2000-03-09
Latest Issue: 2023-02-02

Effective Date: 2023-02-02
Expiry Date: 2025-12-10

Kitemark™ Certificate

No. KM 54019



Group 5b: Non-rewireable plugs with ISO, Class II to BS 1363-1:2016 + A1:2018

Type	Rating	Colour	Reference Report
KE-328 – KEC- insert	250 V (Rough use)	All colours	8411711, 8536403 and 8796555.
KE-328 - GEM insert	250 V (Rough use)	All colours	As above plus 9666634.

Cable fitted: The following cables are satisfactory for incorporation with the variants of Group 5b and are subject to the continuing validity of their approval

Standard	Size mm²	Code	Manufacturer	Approval	Rating (A)
EN 50525-2-11	2 x 0.5	H03VV-F	Kenic	VDE 103853	3
EN 50525-2-11	2 x 0.75	H03VVH2-F	Kenic	VDE 103853	6 / 10 NOTE
EN 50525-2-11	2 x 0.5	H03V2V2-F	Kenic	VDE 40042134	3
EN 50525-2-11	2 x 0.75	H03V2V2-F	Kenic	VDE 40042134	6 / 10 NOTE
EN 50525-2-11	2 x 0.75	H05VV-F	Kenic	VDE 103853	6 / 10 NOTE
EN 50525-2-11	2 x 1	H05VV-F	Kenic	VDE 103853	10
EN 50525-2-11	2 x 1	H05V2V2-F	Kenic	VDE 40042134	10
EN 50525-2-11	2 x 0.75	H05V2V2-F	Kenic	VDE 40042134	6 / 10 NOTE
EN 50525-2-11	2 x 0.5	H03VVH2-F	Kenic	VDE 103853	3
EN 50525-2-11	2 x 0.75	H03VV-F	Kenic	VDE 103853	6 / 10 NOTE
EN 50525-2-11	2 x 0.5	H03V2V2H2-F	Kenic	VDE 40042134	3
EN 50525-2-11	2 x 0.75	H03V2V2H2-F	Kenic	VDE 40042134	6 / 10 NOTE
EN 50525-2-11	2 x 0.75	H05VVH2-F	Kenic	VDE 103853	6 / 10 NOTE
EN 50525-2-11	2 x 1	H05VVH2-F	Kenic	VDE 103853	10
EN 50525-2-11	2 x 0.75	H05V2V2H2-F	Kenic	VDE 40042134	6 / 10 NOTE
EN 50525-2-11	2 x 1	H05V2V2H2-F	Kenic	VDE 40042134	10
EN 50525-2-22	2 x 0.75	H05RR-F	Ta Tun	VDE 40017124	6 / 10 NOTE
EN 50525-2-22	2 x 0.75	H05RN-F	Ta Tun	VDE 40017124	6 / 10 NOTE
EN 50525-2-22	2 x 1	H05RN-F	Ta Tun	VDE 40017124	10
EN 50525-2-22	2 x 1	H05RR-F	Ta Tun	VDE 40017124	6 / 10 NOTE
EN 50525-2-22	2 x 0.75	H05RR-F	Lucky United	VDE 40016757	6 / 10 NOTE
EN 50525-2-22	2 x 0.75	H05RN-F	Lucky United	VDE 40016757	6 / 10 NOTE
EN 50525-2-22	2 x 1	H05RN-F	Lucky United	VDE 40016757	10

Note: Non-rewireable plugs fitted with 0.75 mm² flexible cable size may be rated 10 A when used for cable sets with a maximum flexible cable length of 2 m.

First Issued: 2000-03-09
Latest Issue: 2023-02-02

Effective Date: 2023-02-02
Expiry Date: 2025-12-10

Kitemark™ Certificate

No. KM 54019



Cable fitted (continued): The following cables are satisfactory for incorporation with the variants of Group 5b and are subject to the continuing validity of their approval

Standard	Size mm²	Code	Manufacturer	Approval	Rating (A)
EN 50525-2-22	2 x 1	H05RR-F	Lucky United	VDE 40016757	10
EN 50525-2-21	2 x 0.75	H05BB-F	Lucky United	VDE 40016237	6 / 10 ^{NOTE}
EN 50525-2-21	2 x 1	H05BB-F	Lucky United	VDE 40016237	10

Note: Non-rewireable plugs fitted with 0.75 mm² flexible cable size may be rated 10 A when used for cable sets with a maximum flexible cable length of 2 m.

First Issued: 2000-03-09
Latest Issue: 2023-02-02

Effective Date: 2023-02-02
Expiry Date: 2025-12-10

Kitemark™ Certificate

No. KM 54019

Group 6a: Non-rewireable plugs to BS 1363-1:2016 + A1:2018

Type	Rating	Colour	Reference Report
KE-318	250 V (Rough use)	All colours	9739575

Cable fitted: The following cables are satisfactory for incorporation with the variants of Group 6a and are subject to the continuing validity of their approval

Standard	Size mm ²	Code	Manufacturer	Approval	Rating (A)
EN 50525-2-22	2 x 0.75	H05RR-F	Lucky United	VDE 40016757	6

Group 6a: Non-rewireable plugs with ISOD, Class II, to BS 1363-1:2016 + A1:2018

Type	Rating	Colour	Reference Report
KE-318	250 V (Rough use)	All colours	9739575

Cable fitted: The following cables are satisfactory for incorporation with the variants of Group 6b and are subject to the continuing validity of their approval

Standard	Size mm ²	Code	Manufacturer	Approval	Rating (A)
EN 50525-2-22	2 x 0.75	H05RR-F	Lucky United	VDE 40016757	6

First Issued: 2000-03-09
Latest Issue: 2023-02-02

Effective Date: 2023-02-02
Expiry Date: 2025-12-10